

## Parking:

- Two designated parking spaces, or signs identifying accessible parking within vicinity for people with disabilities
- Accessible parking spaces are sized 4 x 6
- Multilevel parking facilities have an accessible elevator to main level
- Proper signage identifying designated parking spaces
- Parking surface smooth and flat
- Accessible designated parking spaces enforced so that individuals without accessible parking permits do not abuse them
- Is there access from parking to the accessible route

## Walkway:

- Smooth surface to provide easy access by wheelchair
- Proper signage identifying the accessible route
- Flat grade or gradual slope
- Handrails and/or rest stops for longer distances
- Main access routes clear of obstacles such as snow, construction, etc.
- Strong contrast/sufficient lighting along walkway

## Entrance:

- Accessible signage identifying the entrance
- Doorway equipped with an automatic button, automatic slide, or easy open features
- Door width and threshold provide easy access for wheelchair, or scooter users
- Ramp has smooth non-slip surface, grade ratio 1:12, handrail required
- Entrance clear of obstacles such as shoes, snow, mats, etc.
- Strong contrast/sufficient lighting at the entrance
- Accessible alternate entrance
- Accessible emergency exits, door props

## Main Facility:

- Smooth/non slip surface
- Aisles clear of obstacles such as mats, seating, displays, etc.
- Strong contrast/lighting throughout the facility
- Accessible signage/information
- Accessible service counters/tables etc.
- Accessible elevator access to multilevel areas
- Waiting areas provide access for wheelchairs and scooters
- Public telephones have lower level access
- ATM machines and payment terminals have lower level access

## Washrooms:

- Washroom Entrance equipped with easy open/automatic door
- Accessible signage identifying Male/Female/Family washrooms
- Light switches, paper towel and soap dispensers with automatic lower level access
- Lever or automatic taps
- Space under sinks and counter tops for wheelchair access
- Washrooms clear of obstacles such as garbage cans, cleaning supplies etc.
- Sufficient floor space for turning radius and transfers
- Grab bars secured and reinforced
- Coat hooks have lower level access
- Mirrors angled for lower level access
- Emergency call button has lower level access
- Pull down wall table
- Towel dispenser with no garbage can underneath them



For more information call or visit  
**Independent Living Centre Kingston**  
298 Concession St., Kingston, Ontario K7K 2C1  
Ph: 613-542-8353 \* TTY: 613-542-8371 \* Fax: 613-542-4783  
Email: [info@ilckingston.com](mailto:info@ilckingston.com) \* Web: [www.ilckingston.com](http://www.ilckingston.com)